

1370.0210 ILLUMINATION.

Subpart 1. **Minimum illumination.** At least five foot candles of illumination must be provided at floor level inside the storm shelter and at exits.

Subp. 2. **Source.** An emergency lighting system must be supplied from storage batteries or an on-site generator installed in accordance with the requirements of chapter 1315.

Statutory Authority: *MS s 16B.59 to 16B.73; 326B.02; 326B.101 to 326B.151*

History: *12 SR 2251; L 2007 c 140 art 4 s 61; art 13 s 4; L 2008 c 337 s 64; 35 SR 1427*

Published Electronically: *March 23, 2011*